

**MONTHLY REPORT ON THE GREEN DROP WASTE WATER QUALITY COMPLIANCE FOR
UTHUKELA DISTRICT MUNICIPALITY
MONTH : JUNE 2020**

Compiled by : GENERAL MANAGER: MUNICIPAL HEALTH SERVICES & WSA

Reference No. :

Routing

Manco : 07/2020

Portfolio (WSH) : 07/2020

Exco : 07/2020

Council : 07/2020

1. PURPOSE

For the committee to note the Green Drop Waste Water quality compliance report per system for the month of June 2020.

2. BACKGROUND / DISCUSSION

The Green Drop regulation process measures and compares the results of the performance of the Water Services Authorities and their Providers and subsequently rewards or penalizes according to the minimum requirements.

The program focuses on the entire business of the municipal wastewater services. The risk analysis focuses on the wastewater treatment function. This allows the regulator to have insight into the treatment components of the municipal business; it also allows the municipality to identify and prioritize the critical risk areas within its Waste Water Treatment Plants processes and to take the necessary corrective measures in order to mitigate the risks. On the 1st of October 2018, the Green Drop Certification programme migrated to the DWS Integrated Regulatory Information System.

3.1 REPORT

WASTE WATER:

Sewage treatment is the process of removing contaminants from wastewater, primary from household sewage and industries. The treatment process includes physical, chemical and biological processes to remove these contaminants and produce environmentally safe treated wastewater.

WASTE WATER QUALITY INDICATORS:

Quality indicators are determined through Laboratory tests to assess suitability of wastewater for disposal or re-use. The tests selected measure physical, chemical and biological characteristics of the wastewater.

During the month of June 2020, nine (9) Waste Water Treatment Works were monitored. The Wembezi Ponds control samples were taken but due to no outflow, no compliance sample was taken. Therefore, no values are included in the attached Waste Water Quality Compliance Report.

3.1.1 Microbiological quality: Refers to the presence of organisms that cannot be individually seen by the naked eye, such as protozoa, bacteria and viruses. Many of these microbes are associated with the transmission of infectious water-borne diseases such as gastroenteritis and cholera. Microbiological quality can be improved by increasing or optimising chlorination in the final sewage outflow.

During the month of June 2020, no microbiological analysis of Waste Water Treatment Works was conducted due to chemical challenges currently being experienced in the UThukela Internal Laboratory.

3.1.2 Physical quality: Solid material in wastewater can either be dissolved, suspended or settled and can be reduced by conducting on-site analysis and implementing the necessary changes in plant operations. (Example: de-sludge frequently to reduce build-up of sludge)

The Colenso WWTW, Ezakheni WWTW, Ladysmith WWTW and Winterton WWTW complied with the requirements of acceptable physical quality for wastewater.

3.1.3 Chemical quality: Virtually any chemical may be found in wastewater, but routine testing is commonly limited to a few chemical elements of significance. The nature and concentration of dissolved organic substances in domestic/industrial inflow contributes to the organic load on the sewage treatment works. Plant operations needs to be optimised in order to improve the chemical quality of the final effluent.

The Ezakheni WWTW, Colenso WWTW and Winterton WWTW complied with the requirements of acceptable chemical quality for wastewater.

3.2 SAMPLES TAKEN

According to Department of Water and Sanitation General Waste Water Quality Standards, a minimum of 36 samples must be taken. Total number of Waste Water samples taken for the month of June 2020: 7

3.3 INDUSTRIAL SAMPLING

For the month of June 2020, the following industries were sampled and analysed. Accounts were generated and submitted to the Finance Department for billing procedures.

ALFRED DUMA LOCAL MUNICIPALITY

1. Northern Natal Abattoir
2. Lasher Tools
3. Modern Dry Cleaners
4. Pioneer Foods (Sasko)
5. Spotless dry Cleaners
6. Sumitomo Tyres (Dunlop)
7. Transvaal Pressed Nuts & Bolts (TPN)
- 8.

INKOSI LANGALIBALELE LOCAL MUNICIPALITY

1. Clover (Not assessed due to fire damage at the factory – Industry currently non-operational)
2. Eskort Bacon
3. Flamingo Moon
4. Narrowtex
5. Nestle

4. FINANCIAL IMPLICATIONS

2019/2020 Budget

5. LEGISLATION

- 5.1 Waste water discharge standards DWA 2010 guideline
- 5.2 National Water Act (no 36 of 1998)
- 5.3 DWS Green Drop Requirements (IRIS)

6. **ATTACHMENT**

Waste Water Quality Compliance Report for the month of June 2020.

7. **RECOMMENDATION**

1. That the committee notes the report on the June 2020 Green Drop Waste Water Quality Compliance.
2. That the committee supports the submission of the report to Water, Technical and Health Portfolio Committee.

For noting

pp 
BH KHOZA
GENERAL MANAGER: MHS&WSA

14/07/2020

WASTE WATER QUALITY COMPLIANCE REPORT FOR THE MONTH OF MAY 2020 AND JUNE 2020 COMPARATIVE

MICROBIOLOGICAL COMPLIANCE					PHYSICAL COMPLIANCE					CHEMICAL COMPLIANCE				
Discharge Standard: ➤ Faecal Coliform - 1000 cfu/100ml					Discharge Standard: ➤ Electrical Conductivity - < 170ms/m above Intake ➤ pH - 5.5 - 9.5 pH Units ➤ Suspended Solids - 25.0mg/l					Discharge Standard: ➤ COD - 75mg/l ➤ Ortho phosphate - 10mg/l ➤ Ammonia as N - 3mg/l				
WWTW	May - 2020 % Compliance	Rating	June - 2020 % Compliance	Rating	WWTW	May - 2020 % Compliance	Rating	June - 2020 % Compliance	Rating	WWTW	May - 2020 % Compliance	Rating	June - 2020 % Compliance	Rating
Colenso	Not analysed	U	Not analysed	E	Colenso	99.90%	E	99.90%	E	Colenso	50.00%	U	99.90%	E
Ezakheni	Not analysed	U	Not analysed	E	Ezakheni	99.90%	E	99.90%	E	Ezakheni	50.00%	U	99.90%	E
Ladysmith	Not analysed	U	Not analysed	E	Ladysmith	99.90%	E	99.90%	E	Ladysmith	99.90%	E	50.00%	U
Estcourt	Not analysed	U	Not analysed	U	Estcourt	99.90%	E	75.00%	E	Estcourt	0.00%	U	0.00%	U
Wembezi Ponds	No compliance sample available	-	No compliance sample available	-	Wembezi Ponds	No compliance sample available	-	No compliance sample available	-	Wembezi Ponds	No compliance sample available	-	No compliance sample available	-
Ekuvukeni	Not analysed	U	Not analysed	U	Ekuvukeni	75.00%	U	50.00%	U	Ekuvukeni	0.00%	U	0.00%	U
Bergville	Not analysed	U	Not analysed	U	Bergville	66.70%	U	66.70%	E	Bergville	99.90%	E	0.00%	U
Winterton	Not analysed	E	Not analysed	E	Winterton	99.90%	E	99.90%	E	Winterton	50.00%	U	99.90%	E
UTHUKELA DM		U			UTHUKELA DM	91.60%	G	84.47%		UTHUKELA DM	49.97%	U	49.96%	U

Compliance below 80% - U Compliance between 80 - 90% - F Compliance between 90 - 95% - G Compliance above 95% - E